

Message

From: Melissa Duran [mduran@modestogov.com]
Sent: 5/11/2016 10:08:08 PM
To: 'Rohrer, Jim@DTSC' [Jim.Rohrer@dtsc.ca.gov]
CC: Nguyen, Anhtu [Nguyen.Anhtu@epa.gov]
Subject: RE: request of City Well information.
Attachments: DOC.PDF

Both wells were sampled for PCE twice this year so far. We are monitoring every 3 months. Well 6 was sampled on 1/13/16 and 4/13/16 and both results were ND for PCE. Well 7 was sampled on 2/10/16 and 4/13/16 and both results were ND for PCE.

Below I have listed well information for both of the wells and I've also attached the well data from Department of Public Health for both wells. Let me know if you need anything else.

Let me know if you need anything else.

Well	Address	Year Constructed	DHS ID Number	State Well Number	Drilling Method	Total Depth (ft)	Top Screen Interval (ft)	Bottom Screen Interval (ft)	Casing Diameter (in)	Casing Depth (ft)	Gravel Pack	Depth of Annual Vent (ft)	Flow Rate (gpm)	Status	
6	520 E. Morris Avenue (Meinrose & Morris)	1921	5010010-008	095/09E-28C01M	unknown	234	-	-	18	175	no	none	75	950	Active
7	440 W. Morris Avenue (Ensign Park)	1922	5010010-009	095/09E-29B01M	unknown	260	160	210	18/12	-	no	75	75	950	Active


Static Water Levels			
	Well 6	Well 7	
Jan-15	53	48	
Feb-15	52	47	
Mar-15	53	48	
Apr-15	54	48	
May-15	54	49	
Jun-15	55	51	
Jul-15	55	52	
Aug-15	59	54	
Sep-15	59	54	
Oct-15	57.5	53	
Nov-15	56	51	
Dec-15	57	53	
Jan-16	55.5	50	
Feb-16	55	50	
Mar-16	56.5	49	
Apr-16	53	48	

Melissa Duran

Utilities Department-Water Services Division

mduran@modestogov.com

209-342-4596



From: Rohrer, Jim@DTSC [mailto:Jim.Rohrer@dtsc.ca.gov]
Sent: Wednesday, May 11, 2016 2:26 PM
To: Melissa Duran
Cc: Nguyen, Anhthu (Nguyen.Anhtu@epa.gov)
Subject: request of City Well information.

Hi Melissa,

As per our discussion, I am interested in the latest flow rates, water levels, screen intervals and PCE concentration data for City Well 6, City Well 7 and City Well 1. This information will help in our assessment of the Halford's and Elwood's PCE plumes. Thank you.

Regards,

Jim

James Rohrer, P.G.
Project Manager
National Priorities List Unit
California Department of Toxic Substances Control
8800 Cal Center Drive
Sacramento, CA 95826
(916) 255-3709